

---

SAN FRANCISCO UNIFIED SCHOOL DISTRICT  
FACILITIES DESIGN AND CONSTRUCTION

---

**ADDENDUM NO. 1**

**PROJECT:** Computer Lab Renovation  
Lowell High School  
1101 Eucalyptus Drive  
San Francisco, CA 94132  
SFUSD Project Number: 697

**DATE:** July 21, 2014

**OWNER:** San Francisco Unified School District  
135 Van Ness Avenue  
San Francisco, CA 94102

**DSA FILE NO.:** N/A

**DSA APP. NO.:** N/A

Notice is hereby given to all prospective bidders that plans and specifications on the subject project are modified as hereinafter set forth. This Addendum shall be attached to and form a part of the plans and specifications. All bidders must acknowledge receipt of this addendum on the Bid Form. In case of difference with previous addenda or communications, this addendum takes precedence.

It is the responsibility of all bidders to notify all subcontractors from whom they request bids and from whom they accept bids of all changes contained in this addendum.

**PROJECT MANUAL**

**1. Item No. PM-1**

**Reference:** Section 00100 – Notice to Contractors Calling for Bids

**Description:** Revise text for Paragraph 13 as follows:

“**13. Award of Contract.** The Contract for the Work, if awarded, will be by action of the District’s Board of Education to the responsible Bidder submitting the lowest priced responsive **Total Bid Amount (Base Bid and Alternates) Proposal**. The District reserves the right to reject any or all Bid Proposals or to waive any irregularities or informalities in any Bid Proposal or in the bidding. The District also reserves the right to deduct or reject any of the Alternates submitted from the lowest Total Bid Amount Proposal received.”

**2. Item No. PM-2**

**Reference:** Section 12010 – Window Shades

**Description:** In Part 2.3, Materials, include the following text under Paragraph A.2., allowing another alternate fabric for the window shades:

“2a. Acceptable fabric: Ultimate Achievement 802 (Enviroscreen G2) from Mariak, 0.50 mm thick, with metallized coating on exterior face, pvc-free, openness factor at 2%.”

## **DRAWINGS**

**1. Item No. AD1-1**

**Reference: Drawing M0.1, Symbol List, General Notes & Mechanical**  
In the Diffuser, Register and Grille Schedule correct the symbol RG-1 to read as "TG-1, TRANSFER GRILLE".

**2. Item No. AD1-2**

**Reference: Drawing M2.0, First Floor Plans, Demo and New- Mechanical**  
Add the following to SHEET KEYNOTES, below keynote 8:  
"9. ROUTE ¾" CONDENSATE LINE TO (E) SINK TAILPIECE."

**END OF ADDENDUM ITEMS**