



Facilities – Prop A Bond Programs
San Francisco Unified School District
135 Van Ness Avenue, San Francisco, CA 94102

DESCRIPTION OF WORK FOR
INFORMAL BID PROPOSAL

DATE: 3-18-2016

RE: Building B – Miscellaneous Electrical Work at Stair ST02 and ST04
Phillip and Sala Burton High School, 400 Mansell Street, San Francisco, CA, 94131

SCOPE OF WORK:

Contractor shall furnish labor and material to perform miscellaneous electrical work as shown on the attachments; Burton High School – Miscellaneous Electrical Work & attached photographs and Existing Hazardous Materials Conditions Section 00335.

Contractors License Classification:

In accordance with the provisions of California Public Contract Code § 3300, the District requires that Bidders possess the following classification(s) of California Contractors License at the time that the Bid Proposals are opened: **Class B, General Building Contractor or C-10, Electrical**. Any Bidder not so duly and properly licensed shall be subject to all penalties imposed by law.

ADDITIONAL NOTES:

- (1) All equipment and clean-up required by contractor.
- (2) See attached Procedures as outlined in:
 - a. Section 00335 – Existing Hazardous Materials Conditions
 - b. Master Spec 01110 – Hazardous Materials Procedures
 - c. Lead Work Procedures
- (3) Prevailing wages are required on all SFUSD projects and are required at the request of the SFUSD.

PRE-PROPOSAL MEETING DATE:

Monday, March 21, 2016 @ 11:00 AM. in front of main entrance of Burton High School, 400 Mansell Street, San Francisco, CA, 94131

DATE PROPOSAL DUE:

Tuesday, March 22, 2016 @ 4:00 pm. Proposals can be received via hand, email, or fax.

SCHEDULE OF WORK:

If the proposal is accepted and approved by the District, the contractor is expected to start the electrical work on Monday, March 28, 2016 and complete the work by the close of business Monday, 3-28-2016.

CONTACT:

William Chow, SFUSD Senior Project Manager, e-mail: choww@sfusd.edu, P (415) 241-6152 ext. 1555, F (415) 241-6148
Facilities - Proposition A – Bond Programs
135 Van Ness Avenue, Room 207A, San Francisco, CA 94102

BURTON HIGH SCHOOL 400 MANSELL SREET
BURTON HIGH SCHOOL - MISCELLANEOUS ELECTRICAL WORK

BUILDING B

Stair ST01

- No scope or work.

Stair ST02

- 2nd floor landing – Install District furnished light fixture at open j-box
- 3rd floor ceiling – install cover plate over exposed 4 sq j-box

Stair ST03

- No scope of work

Stair ST04

- 3rd floor landing –Install District furnished light fixture in place of (E) cable supported light. Raise light fixture as high as possible based on length of adjacent flex conduit.
- 3rd floor landing - (E) Suspended j-box is not braced. Provide cable braces as needed to secure (E) j-box from movement.
- 3rd floor landing -(E) fire alarm smoke detector is cantilevered off wall. Rotate conduit to align smoke detector against concrete wall over door.









