

---

SAN FRANCISCO UNIFIED SCHOOL DISTRICT  
2011 PROPOSITION A BOND PROGRAM  
**Junipero Serra Elementary School – New Building**

---

**ADDENDUM NO. 1**

**PROJECT: Junipero Serra Elementary School  
New Building**  
625 Holly Park Circle, SF CA 94110

**DATE: June 9, 2016.**

**OWNER: San Francisco Unified School District**  
135 Van Ness Avenue  
San Francisco, CA 94103

**DSA FILE NO.: # 38-1**

**DSA APP. NO.: 01-115374**

Notice is hereby given to all prospective bidders that plans and specifications on the subject project are modified as hereinafter set forth. This Addendum shall be attached to and form a part of the plans and specifications. All bidders must acknowledge receipt of this addendum on the Bid Form. In case of difference with previous addenda or communications, this addendum takes precedence.

It is the responsibility of all bidders to notify all subcontractors from whom they request bids and from whom they accept bids of all changes contained in this addendum.

**BID CLARIFICATIONS**

**ITEM NO. AD1.1**

RFI No. 1 – The information for the clock speaker backbox and equipment is not clear. Please provide a manufacturer and model number .

Response:

***Manufacturer: Simplex***

***Model #: 2975-9013 Time Tone Unit Back box***

***Provide white blank cover plate.***

***Equipment will be provided in Package 2***

***Temp clock to be provided by owner***

**ITEM NO. AD1.2**

RFI No. 2 – The storefront system specification is requiring seismic considerations. Please provide the inter story drift limit.

Response:

***The interstory drift limit between the 1<sup>st</sup> and 2<sup>nd</sup> floor = 3”***

***The interstory drift limit between the 2<sup>nd</sup> floor and the roof level = 3.5”***

**PROJECT MANUAL**

**ITEM NO AD1.3**

Reference: Spec Section 00430 Bid Bond

Description: ***Revise per attached Spec section 00430 – Bid Bond***

**ITEM NO. AD1.4**

Reference: Spec Section 16721 Fire Alarm

Description: ***Revise per attached Spec section 16720 Fire Alarm***

**DRAWINGS**

**ITEM NO AD1.5**

Sketch: No Sketch

Reference: FAP

Description: Revise S.F.U.S.D Project number  
S.F.U.S.D. Project 11502 to read ***S.F.U.S.D. Project 11525***

**ATTACHMENTS:**

**Project Manual:**

00430 – Bid Bond

16720 – Fire Alarm

**END OF  
ADDENDUM #1 ITEMS**