



7. **Item No. PM-7**  
**Reference:** 08520 - Aluminum Windows- Part 2.02 - Materials  
**Description:** Add to 2.02 item H to read... "Typical – STC 35"
8. **Item No. PM-8**  
**Reference:** 08520 - Aluminum Windows- Part 2.04 – Fabrication and Accessories  
**Description:** Delete paragraph 2.04-B.2 reference for divided lights construction on aluminum windows.
9. **Item No. PM-9**  
**Reference:** 08520 - Aluminum Windows- Part 3.04 - Quality Control  
**Description:** Delete mock up, delete paragraph 3.04 B.2.a.1, 2 & 3 entirely.
10. **Item No. PM-10**  
**Reference:** 08520 - Aluminum Windows - Part 3.04 - Quality Control  
**Description:** Change paragraph 3.04- 2.b.1 to read..."Test one window when 10% of the windows have been installed"....
11. **Item No. PM-11**  
**Reference:** 08520 - Aluminum Windows - Part 3.04 - Quality Control  
**Description:** Change paragraph 3.04- 2.b.2 to read..."Test one window when 60% of the windows have been installed"....
12. **Item No. PM-12**  
**Reference:** 08520 - Aluminum Windows - Part 3.04 - Quality Control  
**Description:** add to 3.04- 2.b.3 to read..."Test one window when 90% of the windows have been installed"....
13. **Item No. PM-13**  
**Reference:** 08800 - Glazing- Part 1.04 Submittals – Item C.  
**Description:** Remove acoustical glass, delete reference to glass sample section 1.04-C
14. **Item No. PM-14**  
**Reference:** 08800 - Glazing- Part 2.01 Products  
**Description:** add A2.01. 1  
Manufacturers:  
1. Firelite Glass.  
2. Libbey-Owens-Ford  
3. Old Castle Glass.  
4. PPG Industries.  
5. Nippon Electric Glass Company, Ltd  
6. Substitutions: Section 01630- Product Options and Substitutions
15. **Item No. PM-15**  
**Reference:** 08800 - Glazing- Part 2.01 Products  
**Description:** Add 2.01.A.2.C. to read.... " Vetrotech Saint Global"...
16. **Item No. PM-16**  
**Reference:** 08800 - Glazing- Part 2.01B Products  
**Description:** Remove acoustical glass. Delete reference to glass A2.01.B.J

## **DRAWINGS**

**1. Item No. AD1-1**

**Reference: DRAWING A8.0 - WINDOW TYPES AND WINDOW TREATMENT SCHEDULE**

**Description:** Delete Acoustical glazing from type "J" window. Add laminated glazing STC 50 min.

**2. Item No. AD1-2**

**Reference: DRAWING A.01 TITLE SHEET AND GENERAL**

**Description:** For reference only DSA 01-110526 are part of the DSA Submittal and not part of the Bid set.

**END OF ADDENDUM ITEMS**