











Cleveland Elementary School

455 Athens Street
San Francisco, CA 94112
Tel: (415) 469-4709
Fax: (415) 469-4051



Site Plan

● Accessible ◆ Functionally accessible

| Accessibility | | Location | Condition |
|---|--|---|-----------|
|  | Access path of travel | From north corner of site along Athens Street | ● |
|  | Accessible parking stall | None | |
|  | Passenger loading zone | None | |
|  | Accessible entrance | From gate through play yard to ramp | ● |
|  | Ramp | At Multi-Purpose Room entrance | ● |
|  | Boys' toilet, Girls' toilet, Unisex restroom | See other plans for locations | |
|  | Drinking fountain | See other plans for locations | |
|  | Elevator | None | |
|  | TTY (text telephone) | None | |

School Access Description

Drinking fountains:

- Drinking fountains located in the yard are not ADA compliant.

Cleveland Elementary School

455 Athens Street
San Francisco, CA 94112
Tel: (415) 469-4709
Fax: (415) 469-4051



First Floor Plan

• Accessible ♦ Functionally accessible

| Accessibility | | Location | Condition |
|---------------|--|---|-----------|
| | Access path of travel | Not applicable | |
| | Accessible parking stall | Not applicable | |
| | Passenger loading zone | Not applicable | |
| | Accessible entrance | Portable classrooms via ramps Multi-Purpose Room via ramps | • |
| | Ramp | At portable classrooms and Multi-Purpose Room entrances | • |
| | Boys' toilet, Girls' toilet, Unisex restroom | None on this floor | |
| | Drinking fountain | None on this floor | |
| | Elevator | None | |
| | TTY (text telephone) | None | |

School Access Description

Elevator:

- No elevator access in school. This entire school is not accessible except Multi-Purpose Room and bungalows on first floor.

Restrooms:

- Unisex student restrooms located in bungalows are not ADA compliant.
- Student restrooms located by the stairs are functionally ADA compliant, but they are not accessible. Access to the restrooms is via half flight of stairs.

Cleveland Elementary School

455 Athens Street
San Francisco, CA 94112
Tel: (415) 469-4709
Fax: (415) 469-4051












THIS FLOOR IS NOT ACCESSIBLE



Second Floor Plan

• Accessible ♦ Functionally accessible

| Accessibility | Location | Condition |
|--|--------------------|-----------|
|  Access path of travel | Not applicable | |
|  Accessible parking stall | Not applicable | |
|  Passenger loading zone | Not applicable | |
|  Accessible entrance | Not applicable | |
|  Ramp | Not applicable | |
|  Boys' toilet, Girls' toilet, Unisex restroom | None on this floor | |
|  Drinking fountain | None on this floor | |
|  Elevator | None | |
|  TTY (text telephone) | None | |

School Access Description


- Elevator:**
- No elevator access in school. This entire school is not accessible except Multi-Purpose Room and bungalows on first floor.
- Drinking fountains:**
- Drinking fountain located at corridor is not ADA compliant.
- Restrooms:**
- Unisex staff restrooms located at both end of corridor are functionally ADA compliant, but it is not accessible.

Cleveland Elementary School

455 Athens Street
San Francisco, CA 94112
Tel: (415) 469-4709
Fax: (415) 469-4051












THIS FLOOR IS NOT ACCESSIBLE



Third Floor Plan

• Accessible ♦ Functionally accessible

| Accessibility | Location | Condition |
|--|--------------------|-----------|
|  Access path of travel | Not applicable | |
|  Accessible parking stall | Not applicable | |
|  Passenger loading zone | Not applicable | |
|  Accessible entrance | Not applicable | |
|  Ramp | Not applicable | |
|  Boys' toilet, Girls' toilet, Unisex restroom | None on this floor | |
|  Drinking fountain | None on this floor | |
|  Elevator | None | |
|  TTY (text telephone) | None | |

School Access Description

- Elevator:**
- No elevator access in school. This entire school is not accessible except Multi-Purpose Room and bungalows on first floor.
- Drinking fountains:**
- Drinking fountain located at corridor is not ADA compliant.
- Restrooms:**
- Unisex staff restrooms located at both end of corridor are functionally ADA compliant, but it is not accessible.