











Dr. William L. Cobb Elementary School

2725 California Street
 San Francisco, CA 94115
 Tel: (415)749-3505
 Fax: (415)749-3436



Site Plan

● Accessible ◆ Functionally accessible


Accessibility	Location	Condition
	Access path of travel	from California Street, through playground
	Accessible parking stall	lot off Pine Street
	Passenger loading zone	on California Street, northwest side of school
	Accessible entrance	from California Street, through playground, or from parking lot
	Ramp	not applicable
	Boys' toilet, Girls' toilet, Unisex restroom	not applicable
	Drinking fountain	not applicable
	Elevator	not applicable
	TDD (text telephone)	not applicable

School Access Description

- Parking:**
- There are two marked accessible parking spaces in the lot off Pine Street, although they are not fully compliant.
- Accessibility/Entrance:**
- Access to the main school building is through the playground gates facing California Street at the east side of the building, and along the playground to the entry.
 - Sidewalks along California and Pine Streets are level and in good condition.

Dr. William L. Cobb Elementary School

2725 California Street
San Francisco, CA 94115
Tel: (415)749-3505
Fax: (415)749-3436



First Floor Plan

• Accessible ♦ Functionally accessible

Accessibility		Location	Condition
	Access path of travel	main corridor and elevator	♦
	Accessible parking stall	not applicable	
	Passenger loading zone	not applicable	
	Accessible entrance	from playground at rear of parking lot	♦
	Ramp	inside main entry to corridor	♦
	Boys' toilet, Girls' toilet, Unisex restroom	none	
	Drinking fountain	at playground	•
	Elevator	main corridor, center	•
	TDD (text telephone)	none	

School Access Description

Accessibility/Entrance:

- Access to the main school building at this level is through the playground behind the parking lot. The building entry from Pine Street is not accessible.

Restrooms:

- There are no accessible restrooms on this level.

Drinking fountains:


- The drinking fountain is ADA compliant.

Elevator:

- An elevator is located along the main corridor at the center of the building, accessing all three floor levels.










Dr. William L. Cobb Elementary School

2725 California Street
San Francisco, CA 94115
Tel: (415)749-3505
Fax: (415)749-3436



Second Floor Plan

• Accessible ♦ Functionally accessible

Accessibility	Location	Condition
 	Access path of travel Accessible parking stall	♦
	Passenger loading zone	not applicable
	Accessible entrance	♦
	Ramp	♦
	Boys' toilet, Girls' toilet, Unisex restroom	♦
	Drinking fountain	•
	Elevator	•
	TDD (text telephone)	none

School Access Description

Accessibility/Entrance:

- Access to the main school building at this level is through the playground from California Street. The building entry from California Street is not accessible.

Restrooms:

- Girls' and boys toilets on this level are functionally accessible.

Drinking fountains:


- The drinking fountain is ADA compliant.

Elevator:

- An elevator is located along the main corridor at the center of the building, accessing all three floor levels.










Dr. William L. Cobb Elementary School

2725 California Street
San Francisco, CA 94115
Tel: (415)749-3505
Fax: (415)749-3436



Third Floor Plan

● Accessible ◆ Functionally accessible

Accessibility	Location	Condition
	Access path of travel	main corridor and elevator
	Accessible parking stall	not applicable
	Passenger loading zone	not applicable
	Accessible entrance	not applicable
	Ramp	not applicable
	Boys' toilet, Girls' toilet, Unisex restroom	not applicable
	Drinking fountain	north corridor
	Elevator	main corridor, center
	TDD (text telephone)	not applicable

School Access Description

Restrooms:

Drinking fountains:

Elevator:

- There are no accessible restrooms on this floor.
- The drinking fountain is ADA compliant.
- An elevator is located along the main corridor at the center of the building, accessing all three floor levels.