


## Jose Ortega Elementary School

400 Sargent Street  
 San Francisco, CA 94132  
 Tel: (415)469-4726  
 Fax: (415)584-7972



### Site Plan

• Accessible ♦ Functionally accessible


Accessibility	Location	Condition
Access path of travel	from upper playground, accessible by car only	
Accessible parking stall	at upper playground	
Passenger loading zone	none	
Accessible entrance	from upper playground, accessible by car only	♦
Ramp	to two portable buildings	•
Boys' toilet, Girls' toilet, Unisex restroom	not applicable	
Drinking fountain	not applicable	
Elevator	not applicable	
TDD (text telephone)	not applicable	

### School Access Description

- Parking:**
- There is no parking on the site, except persons with disabilities are allowed to park on the upper playground.
- Accessibility/Entrance:**
- Access to the main school building is only from the upper playground.
  - Sidewalks along the front south side of the school are steep and in poor to good condition.

## Jose Ortega Elementary School

400 Sargent Street  
San Francisco, CA 94132  
Tel: (415)469-4726  
Fax: (415)584-7972



## First Floor Plan

• Accessible ♦ Functionally accessible


Accessibility	Location	Condition
Access path of travel	none	
Accessible parking stall	not applicable	
Passenger loading zone	not applicable	
Accessible entrance	none	
Ramp	not applicable	
Boys' toilet, Girls' toilet, Unisex restroom	not applicable	
Drinking fountains	west corridor	•
Elevator	none	
TDD (text telephone)	none	

### School Access Description

- Restrooms:** • Girls' and boys toilets on this floor are not accessible.
- Drinking Fountains:** • The drinking fountains are ADA compliant.
- Elevator:** • There is no elevator; the first floor is not accessible.

## Jose Ortega Elementary School

400 Sargent Street  
San Francisco, CA 94132  
Tel: (415)469-4726  
Fax: (415)584-7972



## Second Floor Plan

• Accessible ♦ Functionally accessible

Accessibility	Location	Condition
•••••	Access path of travel	west corridor from playground
	Accessible parking stall	not applicable
	Passenger loading zone	not applicable
	Accessible entrance	from upper playground, accessible by car only
	Ramp	not applicable
	Boys' toilet, Girls' toilet, Unisex restroom	unisex restroom at west side
	Drinking fountain	west corridor
	Elevator	none
	TDD (text telephone)	not applicable

### School Access Description

- Restrooms:**
- The unisex restroom on this floor is functionally accessible.
- Drinking fountains:**
- The drinking fountain is ADA compliant.
- Elevator:**
- There is no elevator.