


Jose Ortega Elementary School

400 Sargent Street
 San Francisco, CA 94132
 Tel: (415)469-4726
 Fax: (415)584-7972



Site Plan

● Accessible ◆ Functionally accessible


Accessibility		Location	Condition
●●●●●	Access path of travel	from upper playground, accessible by car only	
	Accessible parking stall	at upper playground	
	Passenger loading zone	none	
	Accessible entrance	from upper playground, accessible by car only	◆
	Ramp	to two portable buildings	●
	Boys' toilet, Girls' toilet, Unisex restroom	not applicable	
	Drinking fountain	not applicable	
	Elevator	not applicable	
	TDD (text telephone)	not applicable	

School Access Description

- Parking:**
- There is no parking on the site, except persons with disabilities are allowed to park on the upper playground.
- Accessibility/Entrance:**
- Access to the main school building is only from the upper playground.
 - Sidewalks along the front south side of the school are steep and in poor to good condition.

Jose Ortega Elementary School

400 Sargent Street
 San Francisco, CA 94132
 Tel: (415)469-4726
 Fax: (415)584-7972



First Floor Plan

• Accessible ♦ Functionally accessible


Accessibility	Location	Condition
Access path of travel	none	
Accessible parking stall	not applicable	
Passenger loading zone	not applicable	
Accessible entrance	none	
Ramp	not applicable	
Boys' toilet, Girls' toilet, Unisex restroom	not applicable	
Drinking fountains	west corridor	•
Elevator	none	
TDD (text telephone)	none	

School Access Description

- Restrooms:** • Girls' and boys toilets on this floor are not accessible.
- Drinking Fountains:** • The drinking fountains are ADA compliant.
- Elevator:** • There is no elevator; the first floor is not accessible.










Jose Ortega Elementary School

400 Sargent Street
San Francisco, CA 94132
Tel: (415)469-4726
Fax: (415)584-7972



Second Floor Plan

• Accessible ♦ Functionally accessible

Accessibility	Location	Condition
  Access path of travel Accessible parking stall	west corridor from playground not applicable	♦
 Passenger loading zone	not applicable	
 Accessible entrance	from upper playground, accessible by car only	♦
 Ramp	not applicable	
 Boys' toilet, Girls' toilet, Unisex restroom	unisex restroom at west side	♦
 Drinking fountain	west corridor	♦
 Elevator	none	
 TDD (text telephone)	not applicable	

School Access Description

Restrooms:

- The unisex restroom on this floor is functionally accessible.

Drinking fountains:

- The drinking fountain is ADA compliant.

Elevator:

- There is no elevator.